

CITY OF BUNKER HILL
NEW ELECTRICAL OR REPLACEMENT OF ELECTRICAL PANEL

The City of Bunker Hill has adopted the [2020 National Electrical Code](#) as produced by NFPA70.

- a. All wiring shall meet all requirements outlined in this code.
- b. All services supplying dwelling units must meet Article 230.67 Surge Protection
- c. IN ADDITION, the City allows ONLY copper conductors beyond the electric meter. NO ALUMINUM CONDUCTORS ALLOWED.
- d. If the electrical panel is replaced, incoming electrical service must be underground from the point of service from CenterPoint.
- e. [CenterPoint Energy Service Standards](#)

[REGISTER OR APPLY TO PURCHASE PERMITS](#)